

Report of Discharge (CSO\SSO\RTB)

version 1.11

(Submission #: HP8-35P7-GXJNK, version 1)

Details

Submission ID HP8-35P7-GXJNK

Status Submitted

Form Input

Report Details

Is this the initial or final discharge report?

Initial

Site/Facility Name:

Lake Mitchell Sewer Authority (former Wexford Co DPW) CM

Permit Number (if applicable):

NA

Sewer System or Treatment Facility Owner

Organization Name

Lake Mitchell Sewer Authority

Phone Type	Number	Extension
------------	--------	-----------

Business	2317750155	
----------	------------	--

Email

operationsoffice@lakemitchellsewer.com

Fax

2317750156

Address

3161 South Lake Mitchell Drive

Cadillac, MI 49601

United States

Facility Address

3161 South Lake Mitchell Drive

Cadillac, MI 49601

Sewer System or Treatment Facility Owner Location

44.2298,-85.5088

3161 South Lake Mitchell Drive, Cadillac, MI

Discharge Details (1 of 1)

SSO Discharge from Grinder Pump Station 9A

Discharge Type:

SSO Discharge

SSO Discharge

The reported discharge is from a private or municipal separate sewer collection system (not a wastewater treatment plant) during wet or dry weather, or a dry weather discharge from a municipal combined sewer collection system.

Is the outfall or discharge area located at a private residential address?

NO

Outfall or Discharge Area Name

Grinder Pump Station 9A

Outfall or Discharge Area Description

Grinder Pump Station 9A - 114 Lily Street

Outfall or Discharge Area Location

44.26852657383043,-85.49527762197496

Has the discharge ended?

YES

Volume Discharged	Unit	Was the volume estimated?
10	Gallons	Yes

Quality of Discharge

Raw Sewage

Please describe the discharge, including the reason for Discharge

The station became inoperable after a component (safe pac) malfunctioned causing the station to fail.

Was the land or surface water impacted by the discharge?

Land impacted only

Name/description of the land impacted:

Station lid and a 2' x 2' area adjacent to the lid

Discharge Event Start

Date	Time
04/17/2021	02:15 pm

Discharge Event End

Date	Time
04/17/2021	02:15 pm

Initial Notification

Organization	Date	Time
Local Health Department	4/18/2021	04:15 pm
Daily Local Newspaper	04/18/2021	04:15 pm

Notification that discharge has concluded.

Organization	Date	Time
Local Health Department	04/18/2021	04:15 pm
Daily Local Newspaper	04/18/2021	04:15 pm

Precipitation Type(s) (Select none if there was no precipitation)

None

Additional Details

Report Submitter

Prefix

NONE PROVIDED

First Name

Donal

Last Name

Brady

Title

NONE PROVIDED

Organization Name

EGLE-WRD

Phone Type

Business

Number

2314295686

Extension**Email**

BradyD6@michigan.gov

Fax

NONE PROVIDED

Address

[NO STREET ADDRESS SPECIFIED]

[NO CITY SPECIFIED], [NO STATE SPECIFIED] [NO ZIP CODE SPECIFIED]

[NO COUNTRY SPECIFIED]

Do you have any additional comments or uploads you would like to provide?

YES

Additional Information

The LMSA attempted to provide notification on 4/17/21 but couldn't due to a problem/error with MiWaters. The LMSA notified the WRD via email at 1:43 AM on 4/18/21. WRD entered the initial report into MiWaters for the LMSA.

Upload addition information, as needed.

[LMSA SSO Grinder St #9 on April 17 2021.msg - 04/19/2021 08:34 AM](#)

Comment

NONE PROVIDED

Attachments

Date	Attachment Name	Context	User
4/19/2021 8:34 AM	LMSA SSO Grinder St #9 on April 17 2021.msg	Attachment	Donal Brady

Status History

	User	Processing Status
4/19/2021 8:20:48 AM	Donal Brady	Draft
4/19/2021 8:36:13 AM	Donal Brady	Submitting
4/19/2021 8:36:17 AM	Donal Brady	Submitted