

Table of Contents

Table of Contents	1
Report of Discharge (CSO\SSO\RTB)	2
(Submission #: HP1-9TDC-RZM7M, version 1)	2
Details	2
Form Input	2
Report Details	2
Discharge Details (1 of 1)	2
SSO Discharge from 44A GPS	2
Additional Details	4
Attachments	4
Status History	4

Report of Discharge (CSO\SSO\RTB)

version 1.11

(Submission #: HP1-9TDC-RZM7M, version 1)

Details

Submission ID HP1-9TDC-RZM7M

Status Submitted

Form Input

Report Details

Is this the initial or final discharge report?

Final

Site/Facility Name:

Lake Mitchell Sewer Authority (former Wexford Co DPW) CM

Permit Number (if applicable):

3112a-1031

Sewer System or Treatment Facility Owner

Organization Name

Lake Mitchell Sewer Authority

Phone Type	Number	Extension
------------	--------	-----------

Business	2317750155	
----------	------------	--

Email

operationsoffice@lakemitchellsewer.com

Fax

2317750156

3161 South Lake Mitchell Drive

Cadillac, MI 49601

US

Facility Address

3161 South Lake Mitchell Drive

Cadillac, MI 49601

Sewer System or Treatment Facility Owner Location

44.2298,-85.5088

3161 South Lake Mitchell Drive, Cadillac, MI

Discharge Details (1 of 1)

SSO Discharge from 44A GPS

Discharge Type:

SSO Discharge

SSO Discharge

The reported discharge is from a private or municipal separate sewer collection system (not a wastewater treatment plant) during wet or dry weather, or a dry weather discharge from a municipal combined sewer collection system.

Is the outfall or discharge area located at a private residential address?

NO

Outfall or Discharge Area Name

44A GPS

Outfall or Discharge Area Description

44A Grinder Pump Station - 120 Teal Court

Outfall or Discharge Area Location

44.26200939999999,-85.49675049999999

120 Teal Ct, Cadillac, MI 49601, USA

Has the discharge ended?

YES

Volume Discharged	Unit	Was the volume estimated?
40	Gallons	Yes

Quality of Discharge

Raw Sewage

Please describe the discharge, including the reason for Discharge

The grinder pump station was inoperable due to wipes binding the pumps. When the pump tripped the breaker and activated the alarm the main fuse blew creating a temporary power loss to the station.

Was the land or surface water impacted by the discharge?

Land impacted only

Name/description of the land impacted:

GPS 44A - adjacent soil to the wetwell.

Discharge Event Start

Date	Time
7/16/2020	12:22 pm

Discharge Event End

Date	Time
7/16/2020	12:40 pm

Name of the wastewater treatment facility that normally receives sewage.

Cadillac Wastewater Treatment Plant

Was the reported discharge caused by a party other than the sewer system owner and out of the control or knowledge of the actions which resulted in the discharge?

YES

Is the sewer system owner in compliance with applicable discharge permits, laws, rules, and orders?

YES

Initial Notification

Organization	Date	Time
Local Health Department	7/16/2020	06:25 pm
Daily Local Newspaper	7/16/2020	06:25 pm

Notification that discharge has concluded.

Organization	Date	Time
Local Health Department	7/16/2020	06:25 pm

Organization	Date	Time
Daily Local Newspaper	7/16/2020	06:25 pm

Precipitation Type(s) (Select none if there was no precipitation)

None

Actions taken to minimize the impact from the discharge(s):

As a precautionary measure, the area impacted was raked, broadcast with lime, and taped off to keep the public from entering the area.

Actions taken, or that will be taken, to prevent this discharge event from reoccurring:

LMSA sends notices to the sewer customers regarding non-flushable items to bring more awareness to the issue.

Additional Details

Report Submitter

Prefix

NONE PROVIDED

First Name Last Name

Sheila Hill

Title

Project Manager

Organization Name

Lake Mitchell Sewer Authority

Phone Type Number Extension

Business 2317750155

Email

operationsoffice@lakemitchellsewer.com

Fax

2317750156

3161 South Lake Mitchell Drive

Cadillac, MI 49601

US

Do you have any additional comments or uploads you would like to provide?

YES

Additional Information

NONE PROVIDED

Upload addition information, as needed.

SSO Notice July 16, 2020.pdf - 07/16/2020 06:40 PM

Comment

NONE PROVIDED

Attachments

Date	Attachment Name	Context	User
7/16/2020 6:40 PM	SSO Notice July 16, 2020.pdf	Attachment	Sheila Hill

Status History

	User	Processing Status

	User	Processing Status
7/16/2020 5:58:22 PM	Sheila Hill	Draft
7/16/2020 6:41:51 PM	Sheila Hill	Submitted