

# Submission Complete

## Report of Discharge (CSO\SSO\RTB)

12/14/2020 Submission HP5-08TE-0NEYD Revision 1 Form Version 1.11

Your submission was successfully submitted. It is recommended that you print and retain a copy of your submission receipt for this transaction using the Print Confirmation feature.

# Report of Discharge (CSO\SSO\RTB)

version 1.11

(Submission #: HP5-08TE-0NEYD, version 1)

## Details

---

**Submission ID** HP5-08TE-0NEYD

**Status** Submitted

## Form Input

---

### Report Details

**Is this the initial or final discharge report?**

Initial

**Site/Facility Name:**

Lake Mitchell Sewer Authority (former Wexford Co DPW) CM

**Permit Number (if applicable):**

NONE PROVIDED

**Sewer System or Treatment Facility Owner**

**Organization Name**

*Lake Mitchell Sewer Authority*

**Phone Type    Number            Extension**

Business        2317750155

**Email**

operationsoffice@lakemitchellsewer.com

**Fax**

2317750156

3161 South Lake Mitchell Drive

Cadillac, MI 49601

US

**Facility Address**

3161 South Lake Mitchell Drive  
 Cadillac, MI 49601

**Sewer System or Treatment Facility Owner Location**

44.2298,-85.5088

3161 South Lake Mitchell Drive, Cadillac, MI

**Discharge Details (1 of 1)**

**SSO Discharge from Lift Station 2A**

**Discharge Type:**

SSO Discharge

**SSO Discharge**

The reported discharge is from a private or municipal separate sewer collection system (not a wastewater treatment plant) during wet or dry weather, or a dry weather discharge from a municipal combined sewer collection system.

**Is the outfall or discharge area located at a private residential address?**

NO

**Outfall or Discharge Area Name**

Lift Station 2A

**Outfall or Discharge Area Description**

Adjacent ground around the wet well

**Outfall or Discharge Area Location**

44.2368027,-85.4563843

210 S Lake Mitchell Dr, Cadillac, MI 49601, USA

**Has the discharge ended?**

YES

Volume Discharged	Unit	Was the volume estimated?
200	Gallons	Yes

**Quality of Discharge**

Raw Sewage

**Please describe the discharge, including the reason for Discharge**

Sewer Technician responded to an alarm at lift station 2A at 12:50 p.m. The lift station is currently operational with one pump. This is due to the age of the station and the deterioration of the interior discharge pipe. There is a hole in the elbow of the discharge line, that has been temporarily patch so the pump could be used in an emergency situation as a backup pump. This station is included in the LMSA's Rural Development project that will rehab the system. There was a failure with the electrical components that created the malfunction with the station. The audio and visual alarm was activated, but the surrounding residents did not report the alarm in time to avoid the SSO. A sewer customer also reported the sewer backed up into his garage.

**Was the land or surface water impacted by the discharge?**

Land impacted only

**Name/description of the land impacted:**

Adjacent land next to the wet well of SPS 2A

**Discharge Event Start**

Date	Time
12/13/2020	12:30 pm

**Discharge Event End**

Date	Time
12/13/2020	12:55 am

**Initial Notification**

Organization	Date	Time
Local Health Department	12/14/2020	12:45 pm
Daily Local Newspaper	12/14/2020	12:45 pm

**Notification that discharge has concluded.**

Organization	Date	Time
Local Health Department	12/14/2020	12:45 pm
Daily Local Newspaper	12/14/2020	12:45 pm

**Precipitation Type(s) (Select none if there was no precipitation)**

None

**Additional Details**

**Report Submitter****Prefix**

NONE PROVIDED

**First Name      Last Name**

Sheila              Hill

**Title**

Project Manager

**Organization Name**

Lake Mitchell Sewer Authority

**Phone Type      Number              Extension**

Business          2317750155

**Email**

operationsoffice@lakemitchellsewer.com

**Fax**

2317750156

3161 South Lake Mitchell Drive

Cadillac, MI 49601

US

**Do you have any additional comments or uploads you would like to provide?**

YES

**Additional Information**

As a precautionary measure, the area impacted was raked, broadcast with lime, and taped off to keep the public from entering the area.

**Upload additional information, as needed.**

NONE PROVIDED

**Comment**

NONE PROVIDED

**Status History**


---

	<b>User</b>	<b>Processing Status</b>
12/14/2020 10:40:46 AM	Sheila Hill	Draft
12/14/2020 12:53:14 PM	Sheila Hill	Submitted